

December 8, 2020

QUESTIONS AND ANSWERS

SET # 5

TO : All Prospective Bidders
FROM : Kiet Vu, Contracts Administrator
SUBJECT : Contract C19123 – Cerone Division Boiler and Propane Tank Replacement

Q9. I cannot tell if the fabrication of the LP Storage vessel is part of the contract. I did see in section 1.3 it only says, “install.” Has VTA already secured the LP Storage vessel from Arcosa Tank, LLC?

A9. VTA has not secured the LP Storage Vessel. The procurement of the 30,000 W.G. ASME pressure vessel is an integral part of this construction contract. Section 1.3 is a generalized and abbreviated summary of the work. The detailed scope of work is defined by the Technical Specifications and Drawings. The contractor awarded Contract C19123 will be required to, among other items of work, furnish and install a new propane gas distribution system. This system includes the 30,000 W.G. ASME pressure vessel, vaporizers, valving, piping, and all related appurtenances. Key plumbing components in the project are identified in the schedules included on drawings P3.1 through P3.3, however other required components are identified in the Technical Specifications and other Contract Drawings.

If you have any questions, please do not hesitate to contact me at Kiet.Vu@vta.org.

Sincerely,



Kiet Vu
Construction Contracts Administrator